


052
T1-32.00
VK



DIN VDE-Bestimmung	: DIN EN 50313-3-4, 01/2011 (Eiszone 2, Windzone 3)
Material	: DA-6-DE-20F5 x 2ES
Beseilung	: 2x3x1 565-AL1/72-ST1A, MZS=4,6,0N/mm ² 110-kV-Mitnahme SH Netz AG, Travl, Ltg Nr 102)
Leiterseil	: 2x3x4 565-AL1/72-ST1A, MZS=4,6,0N/mm ²
Erdsseil	: 2x 264-AL1/34-ST1A
Luftkabel/ sonstige Belegung	: 2x LWL äquivalent zu 264-AL1/34-ST1A, dghl zu LS
Kettenlänge	: 380-kV DA : 6,50m [5000N], VK = 4,70m [1850N], 110-kV DA : 2,80m [600N], VK = 1,77m [950N]
Seitliche Überhöhung	: 15,5 m rechts ————— oder links ————— aufgenommen

Aufgestellt
Bayreuth,
TenneT TSO GmbH

		Deutschland GmbH Wolfenbüttelstraße 29 D-08840 Biberach Leistungsteilung		Maßstab 1 : 2000		Einheit Meter	
01	Umgl. Ltg. Nr. 324	23.11.2015	geka		Datum	Name	
	Umgl. Ltg. Nr. 302	23.11.2015	geka		Bearb.	23.11.2015	poka
					Gepr.	01.12.2015	lp
					Norm	DIN EN 50341-3-4: 01/2011	
					Fachbereich Ltg.		
					 tennet Taking power further		
Zust.	Anderung	Datum	Name	Ursach:			